

NOB HILL WATER ASSOCIATION 2006 ANNUAL WATER QUALITY REPORT

Nob Hill Water Association is pleased to submit our annual Water Quality Report to you, our members. This report contains information about the overall condition of your drinking water. We hope you find this information helpful and informative. We encourage you to take a few minutes to review it. Nob Hill Water is committed to providing our members with high quality drinking water. If you have any questions, comments or suggestions about this report, please contact our office at 966-0272.

About this report...

The federal Safe Drinking Water Act requires that water systems provide their customers with annual reports on the quality of their drinking water. Nob Hill Water is pleased to comply.

In this issue you will find information on:


- ◆ Sources of our water
- ◆ Water test results
- ◆ Water quality contact information

For more water quality information:

EPA Safe Drinking Water Hotline
(800) 426-4791 www.epa.gov/safewater
Washington State Dept. of Health
509-456-3115 www.doh.wa.gov/ehp/dw

WATER SAMPLE RESULTS

The Federal Safe Drinking Water Act (SDWA) of 1996 requires water utilities to produce an annual water quality report on testing and results. The opposite page contains a summary of the latest test results of Nob Hill's water by an independent certified laboratory. The SDWA directs the U.S. Environmental Protection Agency to establish national drinking water standards. In the State of Washington, this program is managed by the State Department of Health. There are two categories of standards: PRIMARY and SECONDARY. Primary standards are set to protect your health. Secondary standards are set for aesthetic qualities such as appearance, taste, odor and color. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **Environmental Protection Agency Safe Drinking Water Hotline at (800) 426-4791**. If you have questions or comments about this report, please call our office.



The Nob Hill Water distribution system is divided into 2 zones. (See Map) Residents in Zone 1 get their water from Well #3. Residents in Zone 2 get their water from a combination of up to 3 wells.

All of our water comes from deep wells. It is pumped from the well, treated with chlorine for disinfection and then fed directly into the system or into one of our reservoirs for storage. We pump an average of 2 million gallons per day in the winter and 6 million gallons per day in the summer.

SPECIAL INFORMATION

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS or other immune systems disorders, some elderly persons and infants can be particularly at risk from infections. These people should seek advice from their health care provider about drinking water.

PRIMARY STANDARDS / HEALTH RELATED STANDARDS

INORGANICS	MCL	ZONE 1		ZONE 2			UNITS	Major sources listed by EPA
		WELL #3	WELL #1	WELL #2	WELL #5			
Antimony	0.006	ND	ND	ND	ND	mg/L	Erosion of natural deposits	
Arsenic	0.05	ND	.0026	ND	ND	mg/L	Erosion of natural deposits	
Barium	2	ND	.027	ND	ND	mg/L	Erosion of natural deposits	
Beryllium	0.004	ND	ND	ND	ND	mg/L	Erosion of natural deposits	
Cadmium	0.005	ND	ND	ND	ND	mg/L	Erosion of natural deposits	
Chromium	0.1	ND	ND	ND	ND	mg/L	Erosion of natural deposits	
Lead♦	0.015	ND	0.0005	ND	ND	mg/L	Erosion of natural deposits	
Mercury	0.002	ND	ND	ND	ND	mg/L	Erosion of natural deposits	
Nickel	0.1	ND	ND	ND	ND	mg/L	Erosion of natural deposits	
Selenium	0.05	ND	ND	ND	ND	mg/L	Erosion of natural deposits	
Silver	0.05	ND	ND	ND	ND	mg/L	Erosion of natural deposits	
Sodium	**	11	47	34	32	mg/L	Erosion of natural deposits	
Thallium	0.002	ND	ND	ND	ND	mg/L	Erosion of natural deposits	
Cyanide	0.2	ND	ND	ND	ND	mg/L	Erosion of natural deposits	
Nitrate	10	ND	.23	.15	.52	mg/L	Erosion of natural deposits	
Nitrite	1	ND	ND	ND	ND	mg/L	Erosion of natural deposits	

ORGANICS

Volatile Organic Chemicals - 61 chemicals tested - none detected

Synthetic Organic Chemicals - none detected

Trihalomehtnes	80	distribution system average 2.9 PPB					by product of chlorination
Haloaletic Acids	60	distribution system average 8.6 PPB					by product of chlorination
BACTERIOLOGICAL							Naturally present in the
Coliform	0	0	0	0	0	#/100 ml	environment

RADIONUCLIDES

Gross Alpha	15 ¹	ND	ND	ND	ND	pCi/L	Erosion of natural deposits
Gross Beta	50	ND	7	ND	4	pCi/L	Erosion of natural deposits

¹ - Excluding Uranium

SECONDARY STANDARDS / AESTHETIC STANDARDS

Copper♦	1.3	ND	.0027	ND	ND	mg/L	Erosion of natural deposits
Iron	0.3	ND	.23	ND	ND	mg/L	Erosion of natural deposits
Manganese	0.05	ND	.0206	0.03	0.026	mg/L	Erosion of natural deposits
Zinc	5	ND	ND	ND	ND	mg/L	Erosion of natural deposits
Chloride	250	ND	12.4	ND	ND	mg/L	Erosion of natural deposits
Fluoride	4	1	.65	1	ND	mg/L	Erosion of natural deposits
Sulfate	250	ND	30.2	ND	ND	mg/L	Erosion of natural deposits

PHYSICAL PARAMETERS

Hardness	**	53	117	52	51	mg/L as CaCO3
Conductivity	700	260	453	260	170	Micromhos/cm 25 deg
Turbidity	1	ND	1	ND	ND	NTU
Color	15	ND	ND	ND	ND	Color Units

Hardness note: To figure grains of hardness, divide mg/L by 17. Nob Hill's water averages approximately 3 grains.

UNREGULATED

Magnesium	**	5.6	11.8	4.8	4.5	mg/L	Erosion of natural deposits
Calcium	**	12	27.2	13	13	mg/L	Erosion of natural deposits

ABBREVIATIONS AND DEFINITIONS:

MCL - Maximum Contaminate Level - The highest level of a contaminant that is allowed in drinking water.

mg/L - Milligrams per liter (1mg/L = 1 PPM)

pCi/L – Picocuries per liter

PPB – Parts per Billion

ND - None detected

NTU – Nephelometric Turbidity Unit

** - No standard has been set

♦- Federal Action Level, not MCL